COMMENTS ON THE SAMPLE OF RUBLE-DILLAR PARTOR FOR TRANSPORMEDS

1. Commanability of items not shed

The transformers appear to be well matched in every/category, except that of specialty transformers, dry type. Specifications for steps and masher of taps are not matched for this category. The weight differentials between US and Soviet types are very large (the Soviet transformers are indicated to be heavier than their US counterparts by a factor of two or more), and the ruble-dollar ratios obtained are much higher than the ratios obtained for other categories. Comparability of the specialty transformers should be rechecked before the ratios shown here are accepted.

2. Representativeness of the sample

Although all major categories of transformers are represented, the average sizes of US power and distribution transformers in most of the categories used in the 1954 Common of Manufactures are smaller than the average sizes for the case categories in the sample. In the USSE, however, the average sizes for the US census categories are probably higher because the Seviet product mix is more heavily saighted with higher capacity power and distribution transformers for industrial use. In addition, in the USSE the electric power industry tends to transmit power at higher voltages than is customary in the US. Specific information about the Soviet product mix of transformers is not available.

Price increases from 1954 to 1955 in the US may account for the apparent difference in average sizes of power and distribution transformers between the 1954 commus and the sample. If prices are assumed to have remained nearly the same in 1955 as in 1954 (as well no the product nix), however, it is concluded that the sizes included in the sample are too large to be representative of the US product mix. The following average prices were calculated from the 1954 Consus of Manufactures:

					Price.
Liga der	od distribution tremsfor ld filled (all voltages type tremsformers above) and a 600			
**************************************	te for distribution and vice; 50 kVA and uder, 15,60		d below		\$ 23
	fil NVA to and including water and below	200 KYA,	15,000		\$ (AL
	26 EVA to and including white and below; and of welltages above 15,	500 KVA B		0	84,422

The sizes of specialty transformers in the sample are probably more representative of the US product mix then are the power and distribution transformers. The largest mingle category of specialty transformers in the 1954

Approved For Release 2000/08/23: CIA-RDP62S00231A000100040075-8

Census of Manufestures, fluorescent lemp bellects, becover, averaged \$2,370 per unit, indicating that sums higher priced items should be included in the shapes. The sample of current transformers is probably adequate for this purpose. He information is available on the Soviet product mix of specialty transformers.

3. Marallaneous connecte

The SIU code for transformers is 3615, not 3612.

Protracte I is not clear. Which is the low voltage rating and which the bigher? The listed ratings usually indicate only that the lower voltages of both the primary and secondary windings can be tapped off. If two prices are relevant, the items should be listed as two separate transformers.